

SCS Global Services does hereby certify that an independent assessment has been conducted on behalf of:

Dynamic Hive, Inc.

10001 Windstream Drive, Columbia, Maryland 21044, United States

For the following product(s):

Demountable Wall Systems:

dHive Single Glass Butt Joint, dHive Double Glass Butt Joint, dHive Single Glass Framed, dHive Double Glass Framed

The product(s) meet(s) all of the necessary qualifications to be certified for the following claim(s):

Indoor Advantage™ Gold

Indoor Air Quality Certified to SCS-105 v4.2-2023

Conforms to the CDPH/EHLB Standard Method (CA 01350) v1.2-2017 (effective January 2017) for the school classroom¹, private office¹, and single-family residence scenarios.

¹Modeled as a Wall Covering

Measured Concentration of Total Volatile Organic Compounds (TVOC): Less than/equal to 0.5 mg/m³ (in compliance with CDPH/EHLB Standard Method v1.2-2017)

Registration # SCS-IAQ-11021

Valid from: May 17, 2024 to May 16, 2025



INDOOR ADVANTAGE GOLD
BUILDING MATERIALS



ANSI National Accreditation Board

ACCREDITED

ISO/IEC 17065

PRODUCT CERTIFICATION
BODY



Nicole Munoz, Vice President, ECS
SCS Global Services

2000 Powell Street, Ste. 600, Emeryville, CA 94608 USA